

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
B-KANAAL WATER

Age : Sex : DOB: 32:U:
ID Number NOT AVAILABLE Tel No (H) NOT AVAILABLE
Other Number U34613 Tel No (C) U34613
Specimen : 17:IF0004576R Lab Ref
Collection Date : 2017-04-04 07:00 728150991
Received Date : 2017-04-04 10:34
Report Date : 2017-04-07 17:15

Clinical Data : SAMPLE/S NOT RECEIVED IN GOOD CONDITION: >24 HOURS
PROCEEDED WITH ANALYSIS AS PER TELECOM WITH ANDREW.
RECEIVED IN PORT ELIZABETH TESTING LAB: 05/04/17 08H30
TEMPERATURE ON RECEIPT: 9 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 05/04/17

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	Description
Procedure	Result
> WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	>2 420
E.COLI/100ml :	26
Treat result with reserve: Water samples received more than 24hrs after collection time. The effect of this on the organisms is not known.	
.....	
: Result Interpretation	:
: 0 = Not Detected / 100ml	:
:	:
: OPERATIONAL WATER QUALITY ALERT VALUES:	:
: -----	:
: If the below stated microbiological limits are exceeded,	:
: an unacceptable health risk is implied:	:
: Total Coliform Bacterial Count/100ml: = < 10	:
: E.coli or Faecal Coliform Bacterial Count/100ml: Not	:

: 2	Lab Ref	Page
GAMTOOS IRRIGATION BOARD	728150991	B-KANAAL WA
TER		
Specimen	Collection Date	Received Date
17:IF0004576R	2017-04-04 07:00	2017-04-04 10:34
15		2017-04-07 17:

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)
: Detected	:
:	:
: NORMATIVE REFERENCE: SANS 241	:
: METHOD USED: SANS 5221 (Colilert)	:
: Sampling done by client.	:
: Test results are specific only to the sample tested.	:
: Samples from the same/similar source may deliver a	:
: different result.	:
: Please note: The test report shall not be reproduced,	:
: except in full, without written approval of the laboratory	:
:.....:	:

Authorised by: MRS MELANI V TONDER on 2017-04-07 16:47:00
 Technical Signatory

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
 END OF REPORT : Total Number of Pages : 2