

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
KOK-SE-PLAAS IRRIGATION WATER

Age : Sex : DOB: 32:U:
ID Number V101630 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 18:IF0010222R Lab Ref
Collection Date : 2018-07-23 12:00 728163444
Received Date : 2018-07-23 12:21
Report Date : 2018-07-25 16:46

Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 24/07/18 08:00
TEMPERATURE ON RECEIPT: 3 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 24/07/18

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	Description
Procedure	Result
> WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	261
E.COLI/100ml	1
.....	
: Result Interpretation	:
: 0 = Not Detected / 100ml	:
:	:
: OPERATIONAL WATER QUALITY ALERT VALUES:	:
: -----	:
: If the below stated microbiological limits are exceeded,	:
: an unacceptable health risk is implied:	:
: Total Coliform Bacterial Count/100ml: = < 10	:
: E.coli or Faecal Coliform Bacterial Count/100ml: Not	:
: Detected	:
:	:
: NORMATIVE REFERENCE: SANS 241	:
: METHOD USED: SANS 5221 (Colilert)	:
: Sampling done by client.	:
: Test results are specific only to the sample tested.	:

	Lab Ref		Page
: 2			
GAMTOOS IRRIGATION BOARD	728163444	KOK-SE-PLAAS IRRIGATION WA	
TER			
Specimen	Collection Date	Received Date	Report Date
18:IF0010222R	2018-07-23 12:00	2018-07-23 12:21	2018-07-25 16:
46			

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)
: Samples from the same/similar source may deliver a	
: different result.	
: Please note: The test report shall not be reproduced,	
: except in full, without written approval of the laboratory	
:.....:	

Authorised by: MRS MELANI V TONDER on 2018-07-25 16:17:00
 Technical Signatory

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
 END OF REPORT : Total Number of Pages : 2