

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
KOUGADAM WATER

Age : Sex : DOB: :U:
ID Number U34613 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 17:IF0004577R Lab Ref
Collection Date : 2017-04-04 07:00 728150989
Received Date : 2017-04-04 10:34
Report Date : 2017-04-07 17:15

Clinical Data : SAMPLE/S NOT RECEIVED IN GOOD CONDITION: >24 HOURS
PROCEEDED WITH ANALYSIS AS PER TELECOM WITH ANDREW.
RECEIVED IN PORT ELIZABETH TESTING LAB: 05/04/17 08H30
TEMPERATURE ON RECEIPT: 9 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 05/04/17

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	Description
Procedure	Result
> WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	1 046
E.COLI/100ml :	0
Treat result with reserve: Water samples received more than 24hrs after collection time. The effect of this on the organisms is not known.	
.....	
: Result Interpretation :	
: 0 = Not Detected / 100ml :	
:	
: OPERATIONAL WATER QUALITY ALERT VALUES: :	
: ----- :	
: If the below stated microbiological limits are exceeded, :	
: an unacceptable health risk is implied: :	
: Total Coliform Bacterial Count/100ml: = < 10 :	
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :	

: 2	Lab Ref	Page
GAMTOOS IRRIGATION BOARD	728150989	KOUGADAM WA
TER		
Specimen	Collection Date	Received Date
17:IF0004577R	2017-04-04 07:00	2017-04-04 10:34
15		2017-04-07 17:

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

: Detected :

: :

: NORMATIVE REFERENCE: SANS 241 :

: METHOD USED: SANS 5221 (Colilert) :

: Sampling done by client. :

: Test results are specific only to the sample tested. :

: Samples from the same/similar source may deliver a :

: different result. :

: Please note: The test report shall not be reproduced, :

: except in full, without written approval of the laboratory :

:.....:

Authorised by: MRS MELANI V TONDER on 2017-04-07 16:47:00
 Technical Signatory

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
 END OF REPORT : Total Number of Pages : 2