

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
KOUGADAM IRRIGATION WATER

Age : Sex : DOB: 32:U:
ID Number U100544 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 17:IF0016188R Lab Ref
Collection Date : 2017-11-22 11:40 728157197
Received Date : 2017-11-22 12:05
Report Date : 2017-11-27 11:44

SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 08:30 23/11/17.
TEMPERATURE ON RECEIPT: 9 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 23/11/17.

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	Description
Procedure	Result
> WATER ANALYSIS	
E.COLI/100ml	: 0
.....	
: Result Interpretation	:
: 0 = Not Detected / 100ml	:
:	:
: OPERATIONAL WATER QUALITY ALERT VALUES:	:
: -----	:
: If the below stated microbiological limits are exceeded,	:
: an unacceptable health risk is implied:	:
: E.coli or Faecal Coliform Bacterial Count/100ml: Not	:
: Detected	:
:	:
: NORMATIVE REFERENCE: SANS 241	:
: METHOD USED: SANS 5221 (Colilert)	:
: Sampling done by client.	:
: Test results are specific only to the sample tested.	:
: Samples from the same/similar source may deliver a	:
: different result.	:

: 2	Lab Ref		Page
GAMTOOS IRRIGATION BOARD	728157197		KOUGADAM IRRIGATION WA
TER			
Specimen	Collection Date	Received Date	Report Date
17:IF0016188R	2017-11-22 11:40	2017-11-22 12:05	2017-11-27 11:
44			

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

: Please note: The test report shall not be reproduced, :
: except in full, without written approval of the laboratory
:.....:

Authorised by: MS SINEAD MORRIS on 2017-11-27 11:40:00
 Technical Signatory
~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
 END OF REPORT : Total Number of Pages : 2