

\*\* Pathologists \*\*  
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory  
PathCare Park  
Neels Bothma Street  
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor  
GAMTOOS IRRIGATION BOARD  
ATT: LEON GRUNDLING  
PO BOX 237  
6335 PATENSIE

Patient  
D-KANAAL IRRIGATION WATER

Age : Sex : DOB: 32:U:  
ID Number V102717 Tel No (H) NOT AVAILABLE  
Other Number NONE Tel No (C) NONE  
Specimen : 19:IF0005512R Lab Ref  
Collection Date : 2019-04-10 10:00 728170413  
Received Date : 2019-04-10 11:28  
Report Date : 2019-04-12 16:48

-----  
Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION  
RECEIVED IN PORT ELIZABETH TESTING LAB: 11/04/19 07:40  
TEMPERATURE ON RECEIPT: 9.5 degrees celcius  
PERFORMED AT 45 Albert Road, Walmer, PE on: 11/04/19

Tests Requested : ~PathCare, : WATER ANALYSIS  
-----

----- Insurance -----  
Source WATER Description  
Procedure Result  
> WATER ANALYSIS  
  
TOTAL COLIFORM CNT/100ml: >2 420  
E.COLI/100ml : 16  
.....  
: Result Interpretation :  
: 0 = Not Detected / 100ml :  
: :  
: OPERATIONAL WATER QUALITY ALERT VALUES: :  
: ----- :  
: If the below stated microbiological limits are exceeded, :  
: an unacceptable health risk is implied: :  
: Total Coliform Bacterial Count/100ml: = < 10 :  
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :  
: Detected :  
: :  
: NORMATIVE REFERENCE: SANS 241 :  
: :  
: METHOD USED: SANS 5221 (Colilert) :  
: :

-----

: 2	Lab Ref		Page
GAMTOOS IRRIGATION BOARD	728170413		D-KANAAL IRRIGATION WA
TER			
Specimen	Collection Date	Received Date	Report Date
19:IF0005512R	2019-04-10 10:00	2019-04-10 11:28	2019-04-12 16:
48			

-----

----- Insurance -----

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

: Sampling done by client. :

: Results in this report apply to the sample as received. :

: Samples from the same/similar source may deliver a :

: different result. :

: Sample information provided may affect validity of :

: results. If there is any reason to doubt the information :

: captured, we suggest re-testing of sample. :

: Please note: The test report shall not be reproduced, :

: exceptin full, without written approval of the :

: laboratory. :

.....

-----

Signed Out by Melani v Tonder on 2019-04-12 16:35:00

For consultation, contact a Pathologist - +27 41 581 2393

~ File [ ] Phone Patient [ ] Appointment [ ] Prescription [ ] Draw File [ ]

END OF REPORT : Total Number of Pages : 2