

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
U KOUGA KANAAL IRRIGATION WATER

Age : Sex : DOB: :U:
ID Number V102395 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 19:IF0000557R Lab Ref
Collection Date : 2019-01-16 09:30 728167735
Received Date : 2019-01-16 11:44
Report Date : 2019-01-21 16:15

Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 07:25 17/01/19
TEMPERATURE ON RECEIPT: 9.5 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 17/01/19

Tests Requested : ~PathCare, : WATER ANALYSIS

----- Insurance -----
Source WATER Description
Procedure Result
> WATER ANALYSIS

E.COLI/100ml : 3
.....
: Result Interpretation :
: 0 = Not Detected / 100ml :
: :
: OPERATIONAL WATER QUALITY ALERT VALUES: :
: ----- :
: If the below stated microbiological limits are exceeded, :
: an unacceptable health risk is implied: :
: Total Coliform Bacterial Count/100ml: = < 10 :
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :
: Detected :
: :
: NORMATIVE REFERENCE: SANS 241 :
: METHOD USED: SANS 5221 (Colilert) :
: Sampling done by client. :

	Lab Ref	Page
: 2	728167735	KOUGA KANAAL IRRIGATION WA
GAMTOOS IRRIGATION BOARD		TER
Specimen	Collection Date	Received Date
	Report Date	
19:IF0000557R	2019-01-16 09:30	2019-01-16 11:44
15		2019-01-21 16:

----- Insurance -----

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

: Test results are specific only to the sample tested. :

: Samples from the same/similar source may deliver a :

: different result. :

: Please note: The test report shall not be reproduced, :

: except in full, without written approval of the laboratory :

:.....:

Authorised by: Sinead Morris on 2019-01-21 15:55:00
 Technical Signatory

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []

END OF REPORT : Total Number of Pages : 2