** Pathologists ** Drs Dietrich, Voigt & Mia PathCare Reference Laboratory PathCare Park Neels Bothma Street Tel: +27 21 596 3400

PracNum: 5200539 FINAL REPORT Page: 1

Doctor

GAMTOOS IRRIGATION BOARD ATT: LEON GRUNDLING

PO BOX 237 6335 PATENSIE

Patient

KOUGADAM IRRIGATION WATER

Age : Sex : DOB: 32:U:

Tel No (H) NOT AVAILABLE

Tel No (C) NONE

 ID Number
 V101630
 Tel No (H) I

 Other Number
 NONE
 Tel No (C) I

 Specimen
 : 18:IF0010223R
 Lab Ref

 Collection Date
 : 2018-07-23 12:00
 728163442

Received Date : 2018-07-23 12:21 Report Date : 2018-07-25 16:46

Clinical Data: SAMPLE/S RECEIVED IN GOOD CONDITION

RECEIVED IN PORT ELIZABETH TESTING LAB: 24/07/18 08:00

TEMPERATURE ON RECEIPT: 3 degrees celcius

PERFORMED AT 45 Albert Road, Walmer, PE on: 24/07/18

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER Description

Procedure Result

> WATER ANALYSIS

TOTAL COLIFORM CNT/100ml: 19 E.COLI/100ml : 0

....... : Result Interpretation

: 0 = Not Detected / 100ml

: OPERATIONAL WATER QUALITY ALERT VALUES:

: ------

: If the below stated microbiological limits are exceeded, :

: an unacceptable health risk is implied:

: Total Coliform Bacterial Count/100ml: = < 10

: E.coli or Faecal Coliform Bacterial Count/100ml: Not

: Detected

: NORMATIVE REFERENCE: SANS 241 : METHOD USED: SANS 5221 (Colilert)

: Sampling done by client.

: Test results are specific only to the sample tested.

	Lab Ref		Page
: 2 GAMTOOS IRRIGATION BOARD	728163442	KOUGAD.	AM IRRIGATION WA
TER Specimen		Received Date	
18:IF0010223R 46		2018-07-23 12:21	
Source WATER Description Procedure Result WATER ANALYSIS (continued)			
: Samples from the same different result. Please note: The test except in full, with the same except in full the same ex	report shall not bout written approva	: be reproduced, : l of the laboratory	
~ File [] Phone Patient []	Technical Signatory	rescription [] Dr	aw File []