

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
PATENSIE IRRIGATION WATER

Age : Sex : DOB: 32:U:
ID Number V103407 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 19:IF0014649R Lab Ref
Collection Date : 2019-10-15 08:30 728175850
Received Date : 2019-10-15 10:50
Report Date : 2019-10-17 17:15

Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 16/10/19 08:10
TEMPERATURE ON RECEIPT: 6.2 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 16/10/19

* a SANAS Accredited Testing Laboratory, No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	----- Insurance -----	Description
Procedure	Result	
> WATER ANALYSIS		
TOTAL COLIFORM CNT/100ml:	>2 420	
E.COLI/100ml	: 9	
.....		
: Result Interpretation		:
: 0 = Not Detected / 100ml		:
:		:
: OPERATIONAL WATER QUALITY ALERT VALUES:		:

: 2	Lab Ref		Page
GAMTOOS IRRIGATION BOARD	728175850		PATENSIE IRRIGATION WA
TER			
Specimen	Collection Date	Received Date	Report Date
19:IF0014649R	2019-10-15 08:30	2019-10-15 10:50	2019-10-17 17:
15			

----- Insurance -----

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

```

: -----
: If the below stated microbiological limits are exceeded,
: an unacceptable health risk is implied:
: Total Coliform Bacterial Count/100ml: = < 10
: E.coli or Faecal Coliform Bacterial Count/100ml: Not
: Detected
:
: NORMATIVE REFERENCE: SANS 241
:
: METHOD USED: SANS 5221 (Colilert)
:
: Sampling done by client.
: Results in this report apply to the sample as received.
: Samples from the same/similar source may deliver a
: different result.
: Sample information provided may affect validity of
: results. If there is any reason to doubt the information
: captured, we suggest re-testing of sample.
: Please note: The test report shall not be reproduced,
: except in full, without written approval of the
: laboratory.
:
: .....
```

Signed Out by Melani v Tonder on 2019-10-17 16:45:00
For consultation, contact a Pathologist - +27 41 581 2393
~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
END OF REPORT : Total Number of Pages : 2