

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
U LYN 106 IRRIGATION WATER

Age : Sex : DOB: :U:
ID Number V103 725 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 20:IF0000577R Lab Ref
Collection Date : 2020-01-16 10:00 728178393
Received Date : 2020-01-16 11:00
Report Date : 2020-01-20 18:13

Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 17/01/2020 07:50
TEMPERATURE ON RECEIPT: 7.5 degrees celcius
PERFORMED AT 45 Albert Road, Walmer, PE on: 17/01/2020

* a SANAS Accredited Testing Laboratory, No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	----- Insurance -----	Description
Procedure	Result	
> WATER ANALYSIS		
TOTAL COLIFORM CNT/100ml:	308	
E.COLI/100ml	: 13	
.....		
: Result Interpretation	:	:
: 0 = Not Detected / 100ml	:	:
:	:	:
: OPERATIONAL WATER QUALITY ALERT VALUES:	:	:

: 2	Lab Ref		Page
GAMTOOS IRRIGATION BOARD	728178393		LYN 106 IRRIGATION WA
TER			
Specimen	Collection Date	Received Date	Report Date
20:IF0000577R	2020-01-16 10:00	2020-01-16 11:00	2020-01-20 18:
13			

Source WATER
 Procedure
 WATER ANALYSIS

----- Insurance -----
 Description
 Result
 (continued...)

```

: -----
: If the below stated microbiological limits are exceeded,
: an unacceptable health risk is implied:
: Total Coliform Bacterial Count/100ml: = < 10
: E.coli or Faecal Coliform Bacterial Count/100ml: Not
: Detected
:
: NORMATIVE REFERENCE: SANS 241
:
: METHOD USED: SANS 5221 (Colilert)
:
: Sampling done by client.
: Results in this report apply to the sample as received.
: Samples from the same/similar source may deliver a
: different result.
: Sample information provided may affect validity of
: results. If there is any reason to doubt the information
: captured, we suggest re-testing of sample.
: Please note: The test report shall not be reproduced,
: except in full, without written approval of the
: laboratory.
:
: .....
```

Signed Out by Melani v Tonder on 2020-01-20 17:47:00
 For consultation, contact a Pathologist - +27 41 581 2393

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
 END OF REPORT : Total Number of Pages : 2