

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
KOK-SE-PLAAS IRRIGATION WATER

Age : Sex : DOB: :U:
ID Number V104020 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 20:IF0005072R Lab Ref
Collection Date : 2020-04-21 09:55 728180868
Received Date : 2020-04-21 10:52
Report Date : 2020-04-23 16:43

Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 16:00 21/04/2020
TEMPERATURE ON RECEIPT: 16.5 degrees celcius
PERFORMED AT 40A Park Drive, PE on: 21/04/2020

Laboratory in voluntary suspension of ISO 17025
accreditation status, due to relocation of premises.

The following CUSTOMER INFORMATION was supplied:

- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Tests Requested : ~PathCare, : WATER ANALYSIS

Source WATER	----- Insurance -----	Description
Procedure		Result
> WATER ANALYSIS		
TOTAL COLIFORM CNT/100ml:	>	2 420
E.COLI/100ml	:	2

```

-----
: 2
GAMTOOS IRRIGATION BOARD Lab Ref 728180868 KOK-SE-PLAAS IRRIGATION WA
TER
Specimen Collection Date Received Date Report Date
20:IF0005072R 2020-04-21 09:55 2020-04-21 10:52 2020-04-23 16:
43
-----

```

```

----- Insurance -----
Source WATER Description
Procedure Result
WATER ANALYSIS (continued...)

```

```

.....
: Result Interpretation :
: 0 = Not Detected / 100ml :
: :
: OPERATIONAL WATER QUALITY ALERT VALUES: :
: ----- :
: If the below stated microbiological limits are exceeded, :
: an unacceptable health risk is implied: :
: Total Coliform Bacterial Count/100ml: = < 10 :
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :
: Detected :
: :
: NORMATIVE REFERENCE: SANS 241 :
: :
: METHOD USED: SANS 5221 (Colilert) :
: :
: Sampling done by client. :
: Results in this report apply to the sample as received. :
: Samples from the same/similar source may deliver a :
: different result. :
: Sample information provided may affect validity of :
: results. If there is any reason to doubt the information :
: captured, we suggest re-testing of sample. :
: Please note: The test report shall not be reproduced, :
: except in full, without written approval of the :
: laboratory. :
: :
: :
.....

```

```

-----
Signed Out by Sinead Morris on 2020-04-23 16:21:00
For consultation, contact a Pathologist - +2741 331 695
~ File [ ] Phone Patient [ ] Appointment [ ] Prescription [ ] Draw File [ ]
END OF REPORT : Total Number of Pages : 2

```