

** Pathologists **
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory
PathCare Park
Neels Bothma Street
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Patient
PATENSIE IRRIGATION WATER

Age : Sex : DOB: :U:
ID Number V104260 Tel No (H) NOT AVAILABLE
Other Number NONE Tel No (C) NONE
Specimen : 20:IF0008461R Lab Ref
Collection Date : 2020-07-07 09:30 728182970
Received Date : 2020-07-07 11:15
Report Date : 2020-07-09 16:16

Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 08/07/2020 08:00
TEMPERATURE ON RECEIPT: 9.5 degrees celcius
PERFORMED AT 40A Park Drive, PE on: 08/07/2020

Laboratory in voluntary suspension of ISO 17025
accreditation status, due to relocation of premises.

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Tests Requested : ~PathCare, : WATER ANALYSIS

----- Insurance -----
Source WATER Description
Procedure Result
> WATER ANALYSIS

TOTAL COLIFORM CNT/100ml: > 2 420
E.COLI/100ml : 4
.....
: Result Interpretation :
: 0 = Not Detected / 100ml :
: :
: OPERATIONAL WATER QUALITY ALERT VALUES: :

: 2	Lab Ref		Page
GAMTOOS IRRIGATION BOARD	728182970		PATENSIE IRRIGATION WA
TER			
Specimen	Collection Date	Received Date	Report Date
20:IF0008461R	2020-07-07 09:30	2020-07-07 11:15	2020-07-09 16:
16			

----- Insurance -----

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

```

: -----
: If the below stated microbiological limits are exceeded,
: an unacceptable health risk is implied:
: Total Coliform Bacterial Count/100ml: = < 10
: E.coli or Faecal Coliform Bacterial Count/100ml: Not
: Detected
:
: NORMATIVE REFERENCE: SANS 241
:
: METHOD USED: SANS 5221 (Colilert)
:
: Sampling done by client.
: Results in this report apply to the sample as received.
: Samples from the same/similar source may deliver a
: different result.
: Sample information provided may affect validity of
: results. If there is any reason to doubt the information
: captured, we suggest re-testing of sample.
: Please note: The test report shall not be reproduced,
: except in full, without written approval of the
: laboratory.
:
: .....

```

Signed Out by Sinead Morris on 2020-07-09 15:41:00
For consultation, contact a Pathologist - +2741 331 695
~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []
END OF REPORT : Total Number of Pages : 2