

\*\* Pathologists \*\*  
Drs Dietrich, Voigt & Mia

PathCare Reference Laboratory  
PathCare Park  
Neels Bothma Street  
Tel : +27 21 596 3400

PracNum: 5200539

FINAL REPORT

Page: 1

Doctor  
GAMTOOS IRRIGATION BOARD  
ATT: LEON GRUNDLING  
PO BOX 237  
6335 PATENSIE

Patient  
KOK-SE-PLAAS IRRIGATION WATER  
ATT: LEON GRUNDLING  
PATENSIE

Age : Sex : DOB: :U: MedAid Num NOT AVAILABLE  
ID Number 21:728191656 Tel No (H) NOT AVAILABLE  
Other Number U105310 Tel No (C) U105310  
Specimen : 21:IF0006225R Lab Ref  
Collection Date : 2021-04-22 10:30 728191656  
Received Date : 2021-04-22 11:40 File No. NOT SUPPLIED/  
Report Date : 2021-04-26 17:45

-----  
Clinical Data : SAMPLE/S RECEIVED IN GOOD CONDITION  
RECEIVED IN PORT ELIZABETH TESTING LAB: 23/04/2021 08:00  
TEMPERATURE ON RECEIPT: 10 degrees celcius  
PERFORMED AT 40A Park Drive, PE on: 23/04/2021

\*\*\*\*\*  
\* a SANAS Accredited Testing Laboratory, No. T0498. \*  
\*\*\*\*\*

The following CUSTOMER INFORMATION was supplied:

- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Primary ICD10 Code(s) : Z76.9

Tests Requested : ~PathCare, : WATER ANALYSIS  
-----

Source WATER	----- Insurance -----	Description
Procedure		Result
> WATER ANALYSIS		

TOTAL COLIFORM CNT/100ml:	1 553
E.COLI/100ml	: 10

.....  
: Result Interpretation :  
: 0 = Not Detected / 100ml :  
: :  
: OPERATIONAL WATER QUALITY ALERT VALUES :  
:

-----

	Lab Ref	Page
: 2	728191656	
GAMTOOS IRRIGATION BOARD		KOK-SE-PLAAS IRRIGATION WA
TER		
Specimen	Collection Date	Received Date
21:IF0006225R	2021-04-22 10:30	2021-04-22 11:40
45		Report Date
		2021-04-26 17:

-----

----- Insurance -----

Source WATER	Description
Procedure	Result
WATER ANALYSIS	(continued...)

:	-----	:
:	If the below stated microbiological limits are exceeded,	:
:	an unacceptable health risk is implied:	:
:	Total Coliform Bacterial Count/100ml: = < 10	:
:	E.coli or Faecal Coliform Bacterial Count/100ml: Not	:
:	Detected	:
:		:
:	NORMATIVE REFERENCE: SANS 241	:
:		:
:	METHOD USED: SANS 5221 (Colilert)	:
:		:
:	Sampling done by client.	:
:	Results in this report apply to the sample as received.	:
:	Samples from the same/similar source may deliver a	:
:	different result.	:
:	Sample information provided may affect validity of	:
:	results. If there is any reason to doubt the information	:
:	captured, we suggest re-testing of sample.	:
:	Please note: The test report shall not be reproduced,	:
:	except in full, without written approval of the	:
:	laboratory.	:
:	.....	:

-----

Signed Out by Melani v Tonder on 2021-04-26 17:11:00  
For consultation, contact a Pathologist - +27 41 581 2393

~ File [ ] Phone Patient [ ] Appointment [ ] Prescription [ ] Draw File [ ]

END OF REPORT : Total Number of Pages : 2