

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125



Practice No:5200539

Report to:
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS IRRIGATION BOARD

Requisition No: 728198961
Specimen No: 0118:BS00048R
Collection Date: 2022-01-18 11:00
Received Date: 2022-01-18 11:43
Reported Date: 2022-02-03 19:44

Patient: (File No: NOT SUPPLIED)
B-KANAAL WATER
Patient ID No: 22:728198961
Age:Sex:DoB: U
Contact No: 0420070382

Guarantor:
GAMTOOS IRRIGATION BOARD
Med Aid: CLIENTS
Member No: NOT AVAILABLE
Contact No: 0835520157

Tests requested: 98 WATER IRRIGATION

ICD10 code(s): Z76.9

Biochemistry

Test Name	Result	Flag	Reference Range
POTASSIUM	1.6		mg/L
	Class 0 (Ideal) <25	Class I (Acceptable) 25 - 50	Class II (Max.Allowable) >50 - 100
PH VALUE	7.1		5.0-9.7 pH units
CHLORIDE	49		0-300 mg/L
CONDUCTIVITY mS/m @ 25 C	22.90		0-170 mS/m
IRON	290		ug/L
	Guidelines: Aesthetic Chronic health		0-300 ug/L 0-2000 ug/L
SODIUM	26		0-200 mg/L
MAGNESIUM	4.3		mg/L
	Class 0 (Ideal) <30	Class I (Acceptable) 30 - 70	Class II (Max.Allowable) >70 - 100
CALCIUM (H2O)	5.0		mg/L
	Class 0 (Ideal) <80	Class I (Acceptable) 80 - 150	Class II (Max.Allowable) >150 - 300
BICARBONATES (H2O)	18.9		mg/L
CARBONATES (H2O)	0		mg/L
SULPHATES	8		mg/L
	Guidelines: Aesthetic Acute health		0-250 mg/L 0-500 mg/L
MANGANESE	130		ug/L
	Guidelines: Aesthetic Chronic health		0-100 ug/L 0-400 ug/L
LANGELIER SATURATION INDEX	-2.6		

A Saturation index value of 0 is perfectly balanced (non-corrosive and non-scaling).
A Negative saturation index value will tend to be corrosive.
A Positive saturation index value will tend to scale

forming.

Na ABSORPTION RATE WATER 2.00

COMMENT:

Sampling done by client.
Test results are specific only to the sample tested.
Samples from the same or similar source may deliver a different result.

Water testing was performed by Pathcare's wholly owned subsidiary, Bemlab Pty Ltd
Accreditation number T0654
For a list of accredited analytes, please contact Bemlab at 021 8531490 or email admin@bemlab.co.za

BORON (WATER ANALYSIS) < 100 0-2400 ug/L

COMMENT:

Guidelines as per SANS 241-1:2011 Drinking water.
DWAf guidelines available on:
http://www.dwaf.gov.za/iwqs/wq_guide/index.asp

Authorised on 2022-01-25 16:37:00

For consultation, contact a Pathologist - 0422934125

H=High, L=Low, *H=Critically High, *L=Critically Low

In rare cases, analytical interference may cause erroneous results.

Please inform pathologist if results and clinical picture do not concur.

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []