

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125

Report to:
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS IRRIGATION BOARD

Requisition No: 728204327
Specimen No: 22:IF0009634R
Collection Date: 2022-07-27 10:10
Received Date: 2022-07-27 10:24
Reported Date: 2022-08-01 11:08

Patient: (RefNo: V107129)
KOUGA DAM IRRIGATION WATER
Patient ID No: N/A
Age:Sex:DoB: U
Contact No: N/A

Guarantor:
GAMTOOS IRRIGATION BOARD
Contact No: 0835520157

Clinical Data: SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 16h38 27/07/22.
TEMPERATURE ON RECEIPT: 6.2 degrees celcius
PERFORMED AT 40A Park Drive
PE on: 28/07/22.

* a SANAS Accredited Testing Laboratory
No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Tests requested: WATER ANALYSIS

Infection Control

Source: WATER

Procedure :	Result
WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	435
E.COLI/100ml	: 2

```

.....
: Result Interpretation :
: 0 = Not Detected / 100ml :
: :
: OPERATIONAL WATER QUALITY ALERT VALUES: :
: ----- :
: If the below stated microbiological limits are exceeded, :
: an unacceptable health risk is implied: :
: Total Coliform Bacterial Count/100ml: = < 10 :
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :
: Detected :
: :
: NORMATIVE REFERENCE: SANS 241 :
: :
: METHOD USED: SANS 5221 (Colilert) :
: :
: Sampling done by client. :
: Results in this report apply to the sample as received. :
: Samples from the same/similar source may deliver a :
: different result. :
: Sample information provided may affect validity of :
: results. If there is any reason to doubt the information :
: captured, we suggest re-testing of sample. :
: Please note: The test report shall not be reproduced, :
: except in full, without written approval of the :
: laboratory. :
.....

```

Signed Out by Melani v Tonder on 2022-08-01 11:01:00
 For consultation, contact a Pathologist - +27 41 581 2393
 ~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []