

# Final Report

Jeffreys Bay Laboratory  
Shop 2, Surfside Centre  
37 Da Gama Road.  
Tel: 042 293 4125



**Report to:**  
**GAMTOOS IRRIGATION BOARD**  
ATT: LEON GRUNDLING  
PO BOX 237  
6335 PATENSIE

**Referred by:** GAMTOOS IRRIGATION BOARD

**Requisition No:** 728208575  
**Specimen No:** 23:IF0000386R  
**Collection Date:** 2023-01-16 10:30  
**Received Date:** 2023-01-16 11:48  
**Reported Date:** 2023-01-18 15:19

**Patient:** ( File No: NOT SUPPLIED Ref  
No: V107698)  
**JANNIE SE GAT KABELJOUS WATER**  
**Patient ID No:** 23:728208575  
**Age:Sex:DoB:** U  
**Contact No:** 0420070382

**Guarantor:**  
**GAMTOOS IRRIGATION BOARD**  
**Med Aid:** CLIENTS  
**Member No:** NOT AVAILABLE  
**Contact No:** 0835520157

**Clinical Data:** JANNIE SE GAT KABELJOUS IRRIGATION  
SAMPLE/S RECEIVED IN GOOD CONDITION  
RECEIVED IN PORT ELIZABETH TESTING LAB: 16H15 16/01/23  
TEMPERATURE ON RECEIPT: 9.6 degrees celcius  
PERFORMED AT 40A Park Drive  
PE on: 17/01/23  
\*\*\*\*\*  
\* a SANAS Accredited Testing Laboratory  
No. T0498. \*  
\*\*\*\*\*  
The following CUSTOMER INFORMATION was supplied:  
- Client contact info  
- Collection date  
- Collection time  
- Sample description / identification  
- Test/s requested

**Tests requested:** WATER ANALYSIS

**ICD10 code(s):** Z76.9

## Infection Control

**Source:** WATER

| Procedure:                | Result |
|---------------------------|--------|
| <b>WATER ANALYSIS</b>     |        |
| TOTAL COLIFORM CNT/100ml: | >2 420 |
| E. COLI/100ml             | : 65   |

```

.....
: Result Interpretation
: 0 = Not Detected / 100ml
:
: OPERATIONAL WATER QUALITY ALERT VALUES:
: -----
: If the below stated microbiological limits are exceeded,
: an unacceptable health risk is implied:
: Total Coliform Bacterial Count/100ml: = < 10
: E.coli or Faecal Coliform Bacterial Count/100ml: Not
: Detected
:
: NORMATIVE REFERENCE: SANS 241
:
: METHOD USED: SANS 5221 - Colilert (T0498);
:              SANS 5221 - Membrane filtration (T0654)
:
: Sampling done by client.
: Results in this report apply to the sample as received.
: Samples from the same/similar source may deliver a
: different result.
: Sample information provided may affect validity of
: results. If there is any reason to doubt the information
: captured, we suggest re-testing of sample.
: Please note: The test report shall not be reproduced,
: except in full, without written approval of the
: laboratory.
.....

```

---

Signed Out by Melani v Tonder on 2023-01-18 14:57:00  
 For consultation, contact a Pathologist - +27 41 581 2393  
 ~ File [ ] Phone Patient [ ] Appointment [ ] Prescription [ ] Draw File [ ]