

Final Report

Jeffreys Bay Laboratory
 Shop 2, Surfside Centre
 37 Da Gama Road.
 Tel: 042 293 4125



Practice No:5200539

Report to:
GAMTOOS IRRIGATION BOARD
 ATT: LEON GRUNDLING
 PO BOX 237
 6335 PATENSIE

Referred by: GAMTOOS IRRIGATION BOARD

Requisition No: 728208580
Specimen No: 0116:BS00041R
Collection Date: 2023-01-16 11:30
Received Date: 2023-01-16 11:52
Reported Date: 2023-01-26 08:34

Patient: (File No: NOT SUPPLIED Ref No: V107 698)
DUPLEX WATER
Patient ID No: 23:728208580
Age:Sex:DoB: U
Contact No: 0420070382

Guarantor:
GAMTOOS IRRIGATION BOARD
Med Aid: CLIENTS
Member No: NOT AVAILABLE
Contact No: 0835520157

Tests requested: WATER IRRIGATION

ICD10 code(s): Z76.9

Biochemistry

Test Name	Result	Flag	Reference Range
POTASSIUM	1.4		mg/L
	Class 0 (Ideal) <25	Class I (Acceptable) 25 - 50	Class II (Max.Allowable) >50 - 100
PH VALUE	7.2		5.0-9.7 pH units
CHLORIDE	45		0-300 mg/L
CONDUCTIVITY mS/m @ 25 C	22.20		0-170 mS/m
IRON	340		ug/L
	Guidelines: Aesthetic Chronic health		0-300 ug/L 0-2000 ug/L
SODIUM	25		0-200 mg/L
MAGNESIUM	4.6		mg/L
	Class 0 (Ideal) <30	Class I (Acceptable) 30 - 70	Class II (Max.Allowable) >70 - 100
CALCIUM (H2O)	5.2		mg/L
	Class 0 (Ideal) <80	Class I (Acceptable) 80 - 150	Class II (Max.Allowable) >150 - 300
BICARBONATES (H2O)	20.3		mg/L
CARBONATES (H2O)	0		mg/L
SULPHATES	7		mg/L
	Guidelines: Aesthetic Acute health		0-250 mg/L 0-500 mg/L
MANGANESE	70		ug/L
	Guidelines: Aesthetic Chronic health		0-100 ug/L 0-400 ug/L
LANGELIER SATURATION INDEX	-2.4		
	A Saturation index value of 0 is perfectly balanced (non-corrosive and non-scaling). A Negative saturation index value will tend to be corrosive.		

A Positive saturation index value will tend to scale forming.

Na ABSORPTION RATE WATER 1.90

COMMENT:

Sampling done by client. Test results are specific only to the sample tested. Samples from the same or similar source may deliver a different result.

Water testing was performed by Pathcare's wholly owned subsidiary, Bemlab Pty Ltd Accreditation number T0654 For a list of accredited analytes, please contact Bemlab at 021 8531490 or email admin@bemlab.co.za

BORON (WATER ANALYSIS) < 100 0-2400 ug/L

COMMENT:

Guidelines as per SANS 241-1:2011 Drinking water. DWAF guidelines available on: http://www.dwaf.gov.za/iwqs/wq_guide/index.asp

Authorised on 2023-01-26 08:08:00

For consultation, contact a Pathologist - 0422934125

H=High, L=Low, *H=Critically High, *L=Critically Low, #=Delta Checked

In rare cases, analytical interference may cause erroneous results.

Please inform pathologist if results and clinical picture do not concur.

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []