

# Final Report

Jeffreys Bay Laboratory  
 Shop 2, Surfside Centre  
 37 Da Gama Road.  
 Tel: 042 293 4125



**Report to:**  
**GAMTOOS IRRIGATION BOARD**  
 ATT: LEON GRUNDLING  
 PO BOX 237  
 6335 PATENSIE

**Referred by: GAMTOOS IRRIGATION BOARD**

**Requisition No:** 728213747  
**Specimen No:** 23:IF0008197R  
**Collection Date:** 2023-07-18 00:00  
**Received Date:** 2023-07-18 11:40  
**Reported Date:** 2023-07-20 17:42

**Patient:** ( File No: NOT SUPPLIED Ref No: V108422)  
**PIET SE GAT IRRIGATION WATER**  
**Patient ID No:** 23:728213747  
**Age:Sex:DoB:** U  
**Contact No:** 0420070382

**Guarantor:**  
**GAMTOOS IRRIGATION BOARD**  
**Med Aid:** CLIENTS  
**Member No:** NOT AVAILABLE  
**Contact No:** 0835520157

**Clinical Data:** COLLECTION TIME NOT SUPPLIED OR UNCLEAR.  
 SAMPLE/S RECEIVED IN GOOD CONDITION  
 RECEIVED IN PORT ELIZABETH TESTING LAB: 16H40 18/07/23  
 TEMPERATURE ON RECEIPT: 13.1 degrees celcius  
 PERFORMED AT 40A Park Drive  
 PE on: 19/07/23  
 \*\*\*\*\*  
 \* a SANAS Accredited Testing Laboratory  
 No. T0498. \*  
 \*\*\*\*\*  
 The following CUSTOMER INFORMATION was supplied:  
 - Client contact info  
 - Collection date  
 - Sample description / identification  
 - Test/s requested

**Tests requested:** WATER ANALYSIS  
**ICD10 code(s):** Z76.9

### Infection Control

Source: WATER

Procedure:	Result
<b>WATER ANALYSIS</b>	
TOTAL COLIFORM CNT/100ml:	2 420
E. COLI/100ml	: 28

```

: Result Interpretation
: 0 = Not Detected / 100ml
:
: OPERATIONAL WATER QUALITY ALERT VALUES:
: -----
: If the below stated microbiological limits are exceeded,
: an unacceptable health risk is implied:
: Total Coliform Bacterial Count/100ml: = < 10
: E.coli or Faecal Coliform Bacterial Count/100ml: Not
: Detected
:
: NORMATIVE REFERENCE: SANS 241
:
: METHOD USED: SANS 5221 - Colilert (T0498);
:              SANS 5221 - Membrane filtration (T0654)
:
: Sampling done by client.
: Results in this report apply to the sample as received.
: Samples from the same/similar source may deliver a
: different result.
: Sample information provided may affect validity of
: results. If there is any reason to doubt the information
: captured, we suggest re-testing of sample.
: Please note: The test report shall not be reproduced,
: except in full, without written approval of the
: laboratory.
  
```

Signed out by Melani v Tonder on 2023-07-20 17:25  
For consultation, contact a Pathologist - +27 41 581 2393  
~ File [ ] Phone Patient [ ] Appointment [ ] Prescription [ ] Draw File [ ]