Final Report

Jeffreys Bay Laboratory Shop 2, Surfside Centre 37 Da Gama Road. Tel: 042 293 4125



Report to: **GAMTOOS IRRIGATION BOARD** Referred by:

GAMTOOS IRRIGATION BOARD

ATT: LEON GRUNDLING **PO BOX 237 6335 PATENSIE**

Patient: (File No: NOT SUPPLIED Ref Requisition No: 728218573 Guarantor:

No: V109201) Specimen No: 24:IF0000823R

JAN SE GAT IRRIGATION WATER Collection Date: 2024-01-22 08:00

Patient ID No: 24:728218573 Received Date: 2024-01-22 11:58 Age:Sex:DoB: U

Reported Date: 2024-01-24 13:16 Contact No: 0420070382

SAMPLE/S RECEIVED IN GOOD CONDITION Clinical Data:

RECEIVED IN PORT ELIZABETH TESTING LAB: 23/01/24 08:15

TEMPERATURE ON RECEIPT: 7.6 degrees celcius PERFORMED AT 40A Park Drive

PE on: 23/01/24

* a SANAS Accredited Testing Laboratory

The following CUSTOMER INFORMATION was supplied:

Client contact info

- Collection date

Collection time as per telecom with Leon Sample description / identification

Test/s requested

Tests requested: WATER ANALYSIS

ICD10 code(s): Z76.9

Infection Control

Source: WATER

Procedure: Result

WATER ANALYSIS

TOTAL COLIFORM CNT/100ml: >2 420 214 E.COLI/100ml

Result Interpretation

0 = Not Detected / 100ml: OPERATIONAL WATER QUALITY ALERT VALUES:

If the below stated microbiological limits are exceeded,

an unacceptable health risk is implied: Total Coliform Bacterial Count/100ml: = < 10 E.coli or Faecal Coliform Bacterial Count/100ml: Not

Detected

NORMATIVE REFERENCE: SANS 241

METHOD USED: SANS 5221 - Colilert (T0498); SANS 5221 - Membrane filtration (T0654)

Sampling done by client.

Results in this report apply to the sample as received. Samples from the same/similar source may deliver a

different result.

Sample information provided may affect validity of

results. If there is any reason to doubt the information captured, we suggest re-testing of sample.
Please note: The test report shall not be reproduced,

except in full, without written approval of the

laboratory.

Generated:2024-01-24 13:16 Page 1 of 2

GAMTOOS IRRIGATION BOARD

Med Aid: CLIENTS

Member No: NOT AVAILABLE

Contact No: 0835520157

Patient: JAN SE GAT IRRIGATION WATER

Signed out by Melani v Tonder on 2024-01-24 12:51
For consultation, contact a Pathologist - +27 41 581 2393
~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []