

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125



Practice No:0774383

Report to:
GAMTOOS IRRIGATION BOARD
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS IRRIGATION BOARD

Requisition No: 728218582

Patient: (File No: V109201)

Guarantor:

Specimen No: 0122:BS00056R
Collection Date: 2024-01-22 11:50
Received Date: 2024-01-22 12:14
Reported Date: 2024-02-01 16:53

K-KAWAAL WATER
Patient ID No: 24:728218582
Age:Sex:DoB: U
Contact No: 0420070382

GAMTOOS IRRIGATION BOARD
Med Aid: CLIENTS
Member No: NOT AVAILABLE
Contact No: 0835520157

Tests requested: WATER IRRIGATION

ICD10 code(s): Z76.9

Biochemistry

Test Name	Result	Flag	Reference Range
POTASSIUM	1.5		mg/L
	Class 0 (Ideal) <25	Class I (Acceptable) 25 - 50	Class II (Max.Allowable) >50 - 100
PH VALUE	7.0		5.0-9.7 pH units
CHLORIDE	37		0-300 mg/L
CONDUCTIVITY mS/m @ 25 C	20.10		0-170 mS/m
IRON	490		ug/L
	Guidelines: Aesthetic Chronic health		0-300 ug/L 0-2000 ug/L
SODIUM	20		0-200 mg/L
MAGNESIUM	3.6		mg/L
	Class 0 (Ideal) <30	Class I (Acceptable) 30 - 70	Class II (Max.Allowable) >70 - 100
CALCIUM (H2O)	4		mg/L
	Class 0 (Ideal) <80	Class I (Acceptable) 80 - 150	Class II (Max.Allowable) >150 - 300
BICARBONATES (H2O)	13.9		mg/L
CARBONATES (H2O)	0		mg/L
SULPHATES	6		mg/L
	Guidelines: Aesthetic Acute health		0-250 mg/L 0-500 mg/L
MANGANESE	90		ug/L
	Guidelines: Aesthetic Chronic health		0-100 ug/L 0-400 ug/L
LANGELIER SATURATION INDEX	-2.9		
	A Saturation index value of 0 is perfectly balanced (non-corrosive and non-scaling). A Negative saturation index value will tend to be corrosive. A Positive saturation index value will tend to scale		

	forming.	
Na ABSORPTION RATE WATER		1.80
COMMENT:	:	
	<p>Sampling done by client. Test results are specific only to the sample tested. Samples from the same or similar source may deliver a different result.</p> <p>Water testing was performed by Pathcare's wholly owned subsidiary, Bemlab Pty Ltd Accreditation number T0654 For a list of accredited analytes, please contact Bemlab at 021 8531490 or email admin@bemlab.co.za</p>	
BORON (WATER ANALYSIS)	< 100	0-2400 ug/L
COMMENT:	.	
	<p>Guidelines as per SANS 241-1:2011 Drinking water. DWAF guidelines available on: http://www.dwaf.gov.za/iwqs/wq_guide/index.asp</p>	

Authorised on 2024-02-01 16:24
 For consultation, contact a Pathologist - 0422934125
 H=High, L=Low, *H=Critically High, *L=Critically Low, #=Delta Checked
 In rare cases, analytical interference may cause erroneous results.
 Please inform pathologist if results and clinical picture do not concur.
 ~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []