

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125



Practice No:0774383

Report to:
GAMTOOS WATER USER ASSOCIATION
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS WATER USER ASSOCIATION

Requisition No: 728226163
Specimen No: 24:IF0013697R
Collection Date: 2024-10-29 09:30
Received Date: 2024-10-29 13:02
Generated On: 2024-10-31 17:33

Patient: (File No: V110460 Ref No: NOT SUPPLIED)
Patient ID No: 24:728226163
Age:Sex:DoB: U
Contact No: 0420070382

Guarantor:
GAMTOOS WATER USER ASSOCIATION
Med Aid: CLIENTS
Member No: NOT AVAILABLE

Clinical Data: SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 08H00 30/10/2024
TEMPERATURE ON RECEIPT: 9.6 degrees celcius
PERFORMED AT 40A Park Drive
PE on: 30/10/2024

* a SANAS Accredited Testing Laboratory
No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time as per telecom with A.Murray
- Sample description / identification
- Test/s requested

Tests requested: WATER ANALYSIS

Referral ICD10 code(s): Z76.9

Infection Control

Source: WATER

Procedure:	Result
WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	>2 420
E. COLI/100ml	: 25

```

: .....
: Result Interpretation
: 0 = Not Detected / 100ml
:
: OPERATIONAL WATER QUALITY ALERT VALUES:
: -----
: If the below stated microbiological limits are exceeded,
: an unacceptable health risk is implied:
: Total Coliform Bacterial Count/100ml: = < 10
: E.coli or Faecal Coliform Bacterial Count/100ml: Not
: Detected
:
: NORMATIVE REFERENCE: SANS 241
:
: METHOD USED: SANS 5221 - Colilert (T0498);
:              SANS 5221 - Membrane filtration (T0654)
:
: Sampling done by client.
: Results in this report apply to the sample as received.
: Samples from the same/similar source may deliver a
: different result.
: Sample information provided may affect validity of
: results. If there is any reason to doubt the information
: captured, we suggest re-testing of sample.
: Please note: The test report shall not be reproduced,
: except in full, without written approval of the
: laboratory.
: .....

```

Signed out by Sinead Morris on 2024-10-31 17:18
 For consultation, contact a Pathologist - +2741 391 5700

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []