

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125



Practice No:0774383

Report to:

**GAMTOOS WATER USER
ASSOCIATION**
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS WATER USER ASSOCIATION

Requisition No: 728235657

Specimen No: 25:IF0015878R
Collection Date: 2025-10-29 07:00
Received Date: 2025-10-29 10:52
Generated On: 2025-11-04 13:08

Patient: (File No: NOT SUPPLIED Ref
No: V111974)

GW 12 DAM/IRRIGATION WATER

Patient ID No: 25:728235657
Age:Sex:DoB: U
Contact No: 0420070382

Guarantor:

**GAMTOOS WATER USER
ASSOCIATION**
Med Aid: CLIENTS
Member No: NOT AVAILABLE

Clinical Data:

** SAMPLE/S NOT RECEIVED IN GOOD CONDITION: >24HRS -
PROCEEDED WITH ANALYSIS AS PER WRITTEN CONSENT ON REQUEST
FORM **
RECEIVED IN PORT ELIZABETH TESTING LAB: 30/10/25 08H00
TEMPERATURE ON RECEIPT: 9.6 degrees celcius
PERFORMED AT 40A Park Drive
PE on: 30/10/25

* a SANAS Accredited Testing Laboratory
No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time: As per email (Andrew Murray)
- Sample description / identification
- Test/s requested: As per telecom (Leon Grundling)

Tests requested: WATER ANALYSIS

Referral ICD10 Z76.9
code(s):

Infection Control

Source: WATER

Procedure:	Result
WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	>2420
TOT FAECAL COLI/100ml :	NOT DONE, INSUFFICIENT VOLUME
E.COLI/100ml :	29

Treat result with reserve: water samples received more than 24hrs after collection time. The effect of this on the organisms is not known.

.....
: Result Interpretation :
: 0 = Not Detected / 100ml :
: :
: OPERATIONAL WATER QUALITY ALERT VALUES: :
: ----- :
: If the below stated microbiological limits are exceeded, :
: an unacceptable health risk is implied: :
: Total Coliform Bacterial Count/100ml: = < 10 :
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :
: Detected :
: :
: NORMATIVE REFERENCE: SANS 241 :
: :
: METHOD USED: SANS 5221 - Colilert (T0498); :
: SANS 5221 - Membrane filtration (T0654) :
: :
: Sampling done by client. :
: Results in this report apply to the sample as received. :
: Samples from the same/similar source may deliver a :
: :

: different result.

: Sample information provided may affect validity of

: results. If there is any reason to doubt the information

: captured, we suggest re-testing of sample.

: Please note: The test report shall not be reproduced,

: except in full, without written approval of the

: laboratory.

.....

Signed out by Melani v Tonder on 2025-11-04 12:53

For consultation, contact a Pathologist - +27 41 581 2393

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []