

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125



Practice No:0774383

Report to:

**GAMTOOS WATER USER
ASSOCIATION**
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS WATER USER ASSOCIATION

Requisition No: 728235662

Specimen No: 25:IF0015918R
Collection Date: 2025-10-29 07:00
Received Date: 2025-10-29 10:49
Generated On: 2025-11-04 13:08

Patient: (File No: NOT SUPPLIED Ref
No: V111974)

GW 18 DAM/IRRIGATION WATER

Patient ID No: 25:728235662
Age:Sex:DoB: U
Contact No: 0420070382

Guarantor:

**GAMTOOS WATER USER
ASSOCIATION**
Med Aid: CLIENTS
Member No: NOT AVAILABLE

Clinical Data:

** SAMPLE/S NOT RECEIVED IN GOOD CONDITION: >24HRS -
PROCEEDED WITH ANALYSIS AS PER WRITTEN CONSENT ON REQUEST
FORM **
RECEIVED IN PORT ELIZABETH TESTING LAB: 30/10/25 08H00
TEMPERATURE ON RECEIPT: 9.6 degrees celcius
PERFORMED AT 40A Park Drive
PE on: 30/10/25

* a SANAS Accredited Testing Laboratory
No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time: As per email (Andrew Murray)
- Sample description / identification
- Test/s requested: As per telecom (Leon Grundling)

Tests requested: WATER ANALYSIS

Referral ICD10 Z76.9
code(s):

Infection Control

Source: WATER

Procedure:	Result
WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	1986
TOT FAECAL COLI/100ml :	NOT DONE, INSUFFICIENT VOLUME
E.COLI/100ml :	1
Treat result with reserve: water samples received more than 24hrs after collection time. The effect of this on the organisms is not known. : If FAECAL COLIFORMS are also a testing requirement, : please submit ADDITIONAL 100ml water with next submission: : (200ml in TOTAL). : : Result Interpretation : 0 = Not Detected / 100ml : : OPERATIONAL WATER QUALITY ALERT VALUES: : ----- : If the below stated microbiological limits are exceeded, : an unacceptable health risk is implied: : Total Coliform Bacterial Count/100ml: = < 10 : E.coli or Faecal Coliform Bacterial Count/100ml: Not : Detected : : NORMATIVE REFERENCE: SANS 241 : : METHOD USED: SANS 5221 - Colilert (T0498); :	

: SANS 5221 - Membrane filtration (T0654) :

: :

: Sampling done by client. :

: Results in this report apply to the sample as received. :

: Samples from the same/similar source may deliver a :

: different result. :

: Sample information provided may affect validity of :

: results. If there is any reason to doubt the information :

: captured, we suggest re-testing of sample. :

: Please note: The test report shall not be reproduced, :

: except in full, without written approval of the :

: laboratory. :

: :

Signed out by Melani v Tonder on 2025-11-04 12:55

For consultation, contact a Pathologist - +27 41 581 2393

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []