

Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125



Practice No:0774383

Report to:

**GAMTOOS WATER USER
ASSOCIATION**
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: GAMTOOS WATER USER ASSOCIATION

Requisition No: 728241936

Patient: (Ref No: V113042)

Guarantor:

Specimen No: 26:IF0010925R

U GW19 IRRIGATION WATER

**GAMTOOS WATER USER
ASSOCIATION**

Collection Date: 2026-07-13 10:15

Patient ID No: N/A

Received Date: 2026-07-14 11:06

Age:Sex:DoB: U

Generated On: 2026-07-16 12:44

Contact No: N/A

Clinical Data:

** SAMPLE/S NOT RECEIVED IN GOOD CONDITION: >24HRS -
PROCEEDED WITH ANALYSIS AS PER CONSENT GRANTED ON REQUEST
FORM **
RECEIVED IN PORT ELIZABETH TESTING LAB: 15/07/26 08H40
TEMPERATURE ON RECEIPT: 9.1 degrees celcius
PERFORMED AT 40A Park Drive
PE on: 15/07/26

* a SANAS Accredited Testing Laboratory
No. T0498. *

The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested

Tests requested: WATER ANALYSIS

Infection Control

Source: WATER

Procedure:	Result
WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	>2420
E.COLI/100ml	0
Treat result with reserve: water samples received more than 24hrs after collection time. The effect of this on the organisms is not known. : Result Interpretation : 0 = Not Detected / 100ml : : OPERATIONAL WATER QUALITY ALERT VALUES: : : If the below stated microbiological limits are exceeded, : an unacceptable health risk is implied: : Total Coliform Bacterial Count/100ml: = < 10 : E.coli or Faecal Coliform Bacterial Count/100ml: Not : Detected : : NORMATIVE REFERENCE: SANS 241 : : METHOD USED: SANS 5221 - Colilert (T0498); : SANS 5221 - Membrane filtration (T0654) : : Sampling done by client. : Results in this report apply to the sample as received. : Samples from the same/similar source may deliver a : different result. : Sample information provided may affect validity of : results. If there is any reason to doubt the information : captured, we suggest re-testing of sample. :	

: Please note: The test report shall not be reproduced,

: except in full, without written approval of the

: laboratory.

.....

Signed out by Sinead Morris on 2026-07-16 12:32

For consultation, contact a Pathologist - +27 41 391 5700

~ File [] Phone Patient [] Appointment [] Prescription [] Draw File []