Final Report

Jeffreys Bay Laboratory
Shop 2, Surfside Centre
37 Da Gama Road.
Tel: 042 293 4125

Practice No:0774383

Report to:
GAMTOOS WATER USER ASSOCIATION
ATT: LEON GRUNDLING
PO BOX 237
6335 PATENSIE

Referred by: **GAMTOOS WATER USER ASSOCIATION**

Requisition No:	**728244374**	***Patient:***	*(**File No:** NOT SUPPLIED)*	***Guarantor:***	
Specimen No:	26:IF0017103R	**GW10 IRRIGATION WATER**		**GAMTOOS WATER USER ASSOCIATION**	
Collection Date:	2026-10-26 14:04	*Patient ID No:*	26:728244374	*Med Aid:*	CLIENTS
Received Date:	2026-10-26 15:38	*Age:Sex:DoB:*	U	*Member No:*	NOT AVAILABLE
Generated On:	2026-10-31 12:21	*Contact No:*	0420070382		

Clinical Data:
```
SAMPLE/S RECEIVED IN GOOD CONDITION
RECEIVED IN PORT ELIZABETH TESTING LAB: 27/10/26 16:30
TEMPERATURE ON RECEIPT: 8  degrees celcius
PERFORMED AT 40A Park Drive
 PE on: 28/10/26
************************************************************
   * a SANAS Accredited Testing Laboratory
 No. T0498. *
************************************************************
The following CUSTOMER INFORMATION was supplied:
- Client contact info
- Collection date
- Collection time
- Sample description / identification
- Test/s requested
```

Tests requested: WATER ANALYSIS

Referral ICD10 code(s): Z76.9

Infection Control

Source: **WATER**

Procedure:	Result
WATER ANALYSIS	
TOTAL COLIFORM CNT/100ml:	>2420
E.COLI/100ml :	42

```
:.....................................................:
: Result Interpretation                               :
: 0 = Not Detected / 100ml                            :
:                                                     :
: OPERATIONAL WATER QUALITY ALERT VALUES:             :
: -------------------------------------              :
: If the below stated microbiological limits are exceeded, :
: an unacceptable health risk is implied:             :
: Total Coliform Bacterial Count/100ml: = < 10        :
: E.coli or Faecal Coliform Bacterial Count/100ml: Not :
: Detected                                            :
:                                                     :
: NORMATIVE REFERENCE: SANS 241                       :
:                                                     :
: METHOD USED: SANS 5221 - Colilert (T0498);          :
:              SANS 5221 - Membrane filtration (T0654) :
:                                                     :
: Sampling done by client.                            :
: Results in this report apply to the sample as received. :
: Samples from the same/similar source may deliver a  :
: different result.                                   :
: Sample information provided may affect validity of  :
: results. If there is any reason to doubt the information :
: captured, we suggest re-testing of sample.          :
: Please note: The test report shall not be reproduced, :
: except in full, without written approval of the     :
: laboratory.                                         :
```

. . . . . .

Signed out by Sinead Morris on 2026-10-31 12:14
For consultation, contact a Pathologist - +27 41 391 5700
~ File [ ] Phone Patient [ ] Appointment [ ] Prescription [ ] Draw File [ ]